

3-2-89  
12.3844

# CITY OF SEATTLE

503 SEATTLE MUNICIPAL BLDG., SEATTLE 98104

Phone 625-2301

## REPORT OF INSPECTOR

Electrical Permit No. **665376** Was issued \_\_\_\_\_, 19\_\_\_\_  
To \_\_\_\_\_ Owner  
As authority to \_\_\_\_\_  
At No. \_\_\_\_\_

### "Corrections"

3-2-89 Batt → OK to cover feeder conduct from bayhouse to blinker building.  
→ OK to concrete encase vehicle service recepts.  
→ Code requires 15' max service raceways inside building like.  
From entrance from concrete encasement to exterior wall is 25'.  
☐ Verify exposed service raceway not subject to severe mechanical injury.  
☐ 3 phase 3 wire ungrounded separately derived systems are allowed only by written permission from this department and as provided with required ground fault detection and alarm monitoring system.

DATE OF VISIT	MADE BY	REMARKS
		O.K. FOR COVERING
		O.K. TO CONNECT SERVICE (SUBJECT TO CITY LIGHT)
		FINAL O.K.

USEPA SF  
1261476

# WARNING

The above corrections must be made promptly and this office notified at once by Permit Number for reinspection. It is unlawful to lath and plaster or otherwise conceal electrical work before same is OK'd.

CALL FOR FINAL INSPECTION AND APPROVAL BY  
THE SEATTLE DEPARTMENT OF CONSTRUCTION AND LAND USE

AGC2F000715